

# CITY OF PETERSBURG

## ANNUAL WATER QUALITY REPORT

### 2025

The City of Petersburg strives to provide the best quality drinking water possible. The purpose of this report is to provide you with information about your drinking water. The report explains to you where your water comes from and the treatment it receives before it reaches your tap. The report also lists all of the contaminants detected in your water and an explanation of all violations in the past year.

#### Where Does My Water Come From?

In late 2003 we switched over to Monroe water. The Monroe Water Treatment Plant draws water from the Western Basin of Lake Erie. This great lake contains over 116 cubic miles of water! Two water intakes gravity feed water to their onshore pumping station. From there it is pumped approximately eight miles to their treatment plant. The State performed an assessment of our source water to determine the susceptibility or the relative potential of contamination. The susceptibility rating is on a seven-tiered scale from "very-low" to "very-high" based on geologic sensitivity, water chemistry and contamination sources. The susceptibility of our source is highly susceptible, given land uses and potential contaminant sources within the source water area. However, the Monroe treatment plant has effectively treated this source water to meet all drinking water standards.

#### How Is My Water Treated And Purified?

The treatment process consist of a series of steps. First, raw water is drawn from Lake Erie where molluscicide is added for Zebra Mussel control. Once the water reaches the treatment plant, ozone is added for taste and odor control. The water then goes to mixing tanks where aluminum sulfate is added for sedimentation. Chlorine is then added for disinfection (we carefully monitor the amount of chlorine, adding the lowest quantity necessary to protect the safety of your water without compromising taste). At this point, the water is filtered through layers of fine coal and silicate sand. As smaller, suspended particles are removed, and clear water emerges. Finally, fluoride (used to fight tooth decay) and a corrosion inhibitor (used to protect distribution system piping) are added before the water is pumped to sanitized water towers and into your home or business.

This report can be viewed on the City web site at [www.petersburg-mi.com/](http://www.petersburg-mi.com/)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity

#### Substances That Might Be in Drinking Water

- ◆ Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, livestock and wildlife.
- ◆ Inorganic contaminants, such as salts and metals, which can be natural or may result from storm runoff, wastewater discharges, oil and gas production and farming.
- ◆ Organic chemicals, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also originate from agricultural practices, storm runoff and septic systems.
- ◆ Radioactive substances, which can be naturally occurring or be the result of oil and gas production and mining activities.
- ◆ Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm runoff, and residential uses.

In order to ensure that tap water is safe, the U.S. Environmental Protection Agency (EPA) prescribes regulations which limit the amount of certain contaminants in water provided by public water systems.

The City of Petersburg water plant staff collects and tests water samples throughout the distribution system . These tests ensure that the proper chemical levels are maintained and that any contaminants that cannot be removed by treatment are at safe levels.

If you would like more information about your water, please call Harvey Salenbien City of Petersburg

734-279-1978.

## WATER QUALITY DATA

During the past year we have taken hundreds of water samples in order to determine the presence of any biological, inorganic, volatile organic or synthetic organic contaminants. The table below lists all contaminants that were detected in 2025. The state allows us to monitor for certain contaminants less than annually because the concentrations are not expected to change frequently. The most recent results of these test are also included in the table. Any violations are printed in **bold**, and an explanation of each violation is provided on page 3.

### Terms and Abbreviations:

- **Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as possible using the best available treatment technology.
- **Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected health risk.
- **Maximum residual disinfectant level goal (MRDLG)** means the level of drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **Maximum residual disinfectants level (MRDL)** means the highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of disinfectant is necessary for control of microbial contaminants.
- **Action Level (AL):** The concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow.
- **pCi/L** - picocuries per liter
- **ND** – not detected
- **TT** – treatment technique (a required process intended to reduce the level of a contaminant in drinking water).
- **NTU** – Nephelometric Turbidity Units
- **ppb** – parts per billion or micrograms per liter
- **ppm** – parts per million or milligrams per liter
- **N/A** – not applicable

Contaminant	MCL	MCLG	Petersburg Water	Range of Detections <sup>1</sup>	Sample Date	Violation	Typical Source of Contaminant
Turbidity (NTU)	TT=1.0 <sup>2</sup>	N/A	Single Highest Measurement = .04 NTU	.02-.04	2025	No	Soil Runoff
Bromate (ppb)	10	0	.40	N.D.-1.60	2025	No	By-product of drinking water disinfection
Fluoride (ppm)	4	4	Amount detected .71	0.42-0.77	2025	No	Erosion of natural deposits; water additive that promotes strong teeth discharge from fertilizer and aluminum factories
Sodium (ppm)	N/A	N/A	10	NA	2025	No	Erosion of natural deposits
Chlorine (ppm)	4.0	4.0	1.05	0.42-1.50	2025	No	Water additive used to control microbes

<sup>2</sup> Turbidity must be less than or equal to 0.3 NTU in at least 95% of the measurements taken throughout the month. Turbidity at the filter confluence point can NEVER, ever be > 1.0 NTU

Contaminant	MCL	MCLG	Petersburg Water	Range of Detections <sup>1</sup>	Sample Date	Violation	Typical Source of Contaminant
<b>Total Trihalomethanes (ppb)</b>	80	N/A	<i>Highest Annual average = 36.50</i>	20.6-58.6	2025	No	By-product of drinking water disinfection
<b>Haloacetic Acids(HAA5s) (ppb)</b>	60	N/A	<i>16.25</i>	9-25	2025	No	By-product of drinking water disinfection
<b>Nitrate(ppm)</b>	10	10	<i>Amount detected = .50</i>	N/A	2025	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
<b>Barium (ppm)</b>	2	2	<i>Amount detected = 0.02</i>	N/A	2025	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of Natural deposits
	<b>MCL</b>	<b>MCLG</b>	<b>Amount Detected</b>	<b>Range of Detections<sup>1</sup></b>	<b>Sample Date</b>	<b>Violation</b>	<b>Typical Source of Contaminant</b>

<b>Copper (ppm)</b>	AL = 1.3	1.3	0	0-06	2025	No	Corrosion of household plumbing systems.
<b>Lead (ppb)</b>	AL= 12	0	0	0	2025	No	Lead Service lines, corrosion of household plumbing including fittings and fixtures; erosion of natural deposits
<b>PFBA</b>	N/A	N/A	3	ND-3ppt	2025	No	Discharge and waste from industrial facilities; stain resistant treatments
<b>PFOA</b>	8	N/A	2	ND-2ppt	2025	No	Discharge and waste from industrial facilities; stain resistant treatments
							Firefighting foam; Discharge from electroplating facilities; discharge and waste from industrial facilities

## INFORMATIONAL STATEMENTS ABOUT THE CHEMICALS DETECTED IN YOUR WATER:

Some people may be more vulnerable to contaminants in drinking water than the general population. Immune-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791)


Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe drinking Water Hotline (800-426-4791)

**Information about lead in Drinking water:** Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. City of Petersburg is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for at least 5 minutes to flush water from both your home plumbing and the lead service line. If you are concerned about lead in your water and wish to have your water tested, contact City of Petersburg - Harvey Salenbien (734-279-1978) for available resources. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

**ABOUT OUR TURBIDITY:** Turbidity in water is caused by the presence of suspended matter, such as clay, silt, finely divided organic matter, and other microscopic organisms. In 2016, we maintained an average turbidity level of 0.06 NTU. The MCL of turbidity is 1.0 NTU and 95% of samples in a given month are required to be below 0.3 NTU or there is a treatment technique violation.

If you have any questions about the chemicals in your water, please call the City of Petersburg at 734-279-1978. This report will not be mailed to every customer. If you would like a copy of this report it can be printed off of the city website at [www.petersburg-mi.com](http://www.petersburg-mi.com) or you may call the City of Petersburg 734-279-1210. We will make arrangements to make sure you receive a copy.

**Service Line Materials** There are approximately 486 service connections in The City. In 2021/2022 The City of Petersburg took on a major project and replaced all Water mains, valves, fire hydrants, water meters and service lines in the city right of way. Upon doing this the contractors found 4 lead service lines and 1 galvanized service line on the home owners side of the curb box. Once the Contractor notified the City, arrangements were made with the home owners to promptly get these lines replaced. The City of Petersburg is confident that there are no lead or galvanized service lines left.



The City of Petersburg Council meets at 6:30 pm on the first and third Monday of each month. Meetings are held at City hall. Please feel free to come and participate.

City of Petersburg  
24 E. Center St.  
Petersburg, Michigan 49270  
734-279-1210